

**ARKANSAS DEVELOPMENT FINANCE AUTHORITY
MULTIFAMILY HOUSING MINIMUM DESIGN STANDARDS**

The following outline of minimum standards must be used in designing Multifamily developments receiving low-income housing tax credits.

Any deviation from these standards must receive prior written approval from the Arkansas Development Finance Authority. In addition to these minimum standards, all developments must be designed in accordance with all federal and state accessibility requirements, Fair Housing requirements, and any applicable local, state and national building codes.

Applicant and architect shall execute separate verifications under oath that the representations set forth in Attachment G, Minimum Design Standards Checklist, will be met in the construction or rehabilitation of the proposed development and that all amenities and energy features represented in the application will be included in the construction or rehabilitation of the proposed development. The general contractor for the development must sign off on Attachment G prior to issuance of the Notice to Proceed.

I. Site Selection Criteria:

- A. New Construction: No waivers or other exceptions of the standards set forth herein will be allowed, including, any request based upon "terrain or unusual characteristics of the site's topography."
- B. Requirements for any development site within the 100-year flood plain: (1) The community where located must be currently participating in the National Flood Insurance Program; (2) Flood Insurance must be obtained and maintained throughout the affordability period; and (3) Any part of the site that will undergo development, i.e., residential buildings, community buildings, playgrounds, swimming pools, recreational areas, sidewalks and parking areas, must be raised to no less than one (1) foot above the flood plain level.

II. Drawing Submission Criteria:

The following documents shall be prepared by a registered architect or engineer licensed to practice in the State of Arkansas.

- A. Site Plan: The following items must be shown.
 - 1. Scale: 1 inch = 40 feet or larger for typical units.
 - 2. North arrow.
 - 3. Locations of existing buildings, utilities, roadways, parking areas if applicable.
 - 4. Existing site/zoning restrictions including setbacks, rights of ways, boundary lines, wetlands, and flood plain.
 - 5. All proposed changes and proposed buildings, parking, utilities, and landscaping.
 - 6. Existing and proposed topography of site.
 - 7. Finished floor height elevations and all new paving dimensions and elevations.
 - 8. Identification of all specialty apartment units, including, but not limited to, designated handicapped accessible and sensory impaired apartment units.
 - 9. Site accessibility design requirements.
- B. Floor Plans:
 - 1. Scale: ¼ inch = 1 foot or larger for typical units.
 - 2. For developments requiring renovation and/or demolition of existing structures, show proposed changes to building components and design, identifying removal and new construction methods.
 - 3. Show room/space layout, identifying each room/space with name and finished space size.
 - 4. Indicate the total gross square foot size, and the net square foot size for each typical unit.
 - 5. For developments involving removal of asbestos and/or lead paint, identify location and procedures for removal.
- C. Elevations and sections for new construction:
 - 1. Scale: 1/8 inch = 1 foot or larger.
 - 2. Building elevations for all sides of each building.
 - 3. Identify all materials to be used on building exteriors and foundations.

Final plans and specifications must be submitted to ADFA two (2) weeks prior to the preconstruction conference.

III. Outline Specifications: Provide a brief description of each specification using the Construction Specification Index format or a similar format:

Example:

DIVISION 2 SITE WORK

Section 02232: Select Material Sub-base Course for Flexible Pavement

- A. General: This section specifies the base course for use with flexible pavement.
- B. Material: Sub-base material shall consist of natural, processed for blends of gravel, stone, sand or screenings and soil or other similar binding or filler material.
- C. Execution: The sub-base material shall be placed on the previously prepared sub-grade. The material shall be placed to the thickness and lines and grades shown.

IV. Building Design Criteria:

A. General Building Standards:

1. Community Laundry: The development's community laundry must consist of at least 1 washer and 1 dryer for every 10 units in the development. Exceptions: a) If all units in the development have washer/dryer connections, then the community laundry must consist of at least 1 washer and 1 dryer for every 15 units in the development; b) If all units in the development have a washer and dryer furnished at no cost to the tenants by the development, then the development is required to provide at least 1 washer and 1 dryer; and c) Developments consisting of Single Family Detached Units exclusively.
2. Senior or Assisted Living Developments: All units in senior or assisted living developments shall be located at the grade level or on an elevator accessible floor.
3. Parking Spaces:
 - a. *Family Developments:* Inclusive of handicap designated parking spaces, 1½ parking spaces must be provided for each unit and 1 guest parking space will be provided for every 4 units.
 - b. *Senior Developments:* Inclusive of handicap designated parking spaces, 1 parking space must be provided for each unit and 1 guest parking space will be provided for every 4 units.
 - c. New construction assisted living developments may request a waiver of the parking spaces required herein. The number of parking spaces for which approval is requested must be reasonable as evidenced by supporting documents and information. A waiver requesting approval of a number of parking spaces that is less than the total number of units will not be considered as reasonable; however, a request to provide only the number of parking spaces equal to the total number of units will not be per se reasonable.

A waiver will not be granted unless land is available to the partnership and will remain available to the partnership which is sufficient to allow construction of the number of parking spaces required but for the waiver. Applicant must have site control over this land, have authority to agree to contract for this reservation of use and allow all restrictive documents to run with the reserved land, and agree in writing to so contract.

4. Single Family Detached Units (SFD): Must: (a) be at least 3 bedroom units with 2 bathrooms; however, up to 20 percent of the units in the development may be 2 bedroom with 2 full bathrooms, if supported by market need; b) have washer and dryer connections in the living area; and (c) have at least a single car garage attached.

B. Minimum Building Standards:

1. Minimum Unit Area Requirements:

- a. Minimum Unit Net Area is measured from the **interior finished face** of the exterior wall to the **centerline** of the common, or party, wall.
- b. Minimum Bedroom Net Area is measured from the interior faces of all walls surrounding each bedroom, excluding closets, mechanical rooms, and storage rooms.
- c. Exceptions to minimum area requirements:
 - (i.) Rehabilitation of existing residential rental units; and
 - (ii.) Assisted Living Developments.

- d. Area included as an entry way to any bedroom shall not be included in the minimum square footage requirements, i.e., if an entry door to a bedroom is not located on one of the four main bedroom walls, the square footage of the area from the bedroom door to the two nearest main bedroom walls shall be excluded from calculation of the required square footage for the bedroom and the unit as a whole.

<u>Unit Type</u>	<u>Number of Bathrooms</u>	<u>Minimum Unit Net Area</u>	<u>Minimum Bedroom Net Area</u>
1 bedroom	1	550 sq ft	100 sq ft
2 bedroom	1.5	750 sq ft	100 sq ft
2 bedroom SFD	2	1000 sq ft	100 sq ft
3 bedroom	2	1000 sq ft	100 sq ft
4 bedroom	2	1200 sq ft	100 sq ft

Unit areas do not include outside storage, covered porches, patios, balconies, etc.

2. Exterior Building Standards:

- a. Exterior building coverings: For new construction, very low maintenance materials are required. Acceptable materials include:
- (i.) Brick;
 - (ii.) High quality vinyl siding with a minimum thickness of .042 and a life time non-prorated limited warranty (50 year) transferable; or
 - (iii.) Cementitious siding.
- All siding materials listed above are required to be 8 inches above the finished floor elevation of the building ground floor, with the exception of concrete patio and covered breezeway areas. Brick or decorative block must be used as an apron material.*
- b. Prefinished fascia and soffit: Vinyl, aluminum or cementitious prefinished panels should be used and must contain vents.
- c. Entry doors: Materials for entry doors are to be metal-clad wood or hollow metal construction. "Peepholes" and deadbolt locks are required in entry doors. Dead bolt locks on entry doors should have "thumb latch" on interior side. Double keyed dead bolt locks are prohibited. All exterior doors must have minimum clear opening width of 34 inches.
- d. Roofing materials: Anti-fungal seal tab shingles over 15 lb. felt paper or metal roof with a minimum 30-year warranty are required with either roofing system.
- e. Gutters and downspouts shall be appropriately designed with a minimum 5" gutter and 2" x 3" downspout. All downspouts shall empty onto concrete splash blocks or piped to an appropriate drain location.
- f. Roof gable vents must be made of aluminum or vinyl materials.
- g. Attics must be vented.
- h. All primary entries should be within a breezeway or have a minimum roof covering of 5 feet deep by 5 feet wide, and should be designed to divert water away from the entry door. Entry pads measuring 5 feet by 5 feet and made of impervious material with a minimum slope of 1/4 inch per foot are required at each primary entry.
- i. Breezeways functioning as fire exits must be constructed of concrete floor/decking material.
- j. Exterior shutters are required on all 100% vinyl or cementitious sided buildings.
- k. Exterior stairway components, such as stringers, steps, risers, handrails, pickets, and structural supports, and porch and patio components, structural and non-structural, either used as part of the building or within the site development, must be constructed from noncombustible materials such as concrete, steel, aluminum or masonry.
- l. Exterior lighting is required at entry doors.
- m. Landscaping: All disturbed areas must be sodded. One 1½" tree per every 2 units. Six 1-gallon shrubs per unit.
- n. Concrete curbing is required along all paved areas throughout the development site, including parking areas.
- o. Sidewalk access to all parking spaces must be provided.
- p. A development sign including the fair housing logo is required.
- q. A minimum of one enclosed trash dumpster or compactor is required.

- r. Continuous asphalt or concrete paved access road must be provided to the entrance of the development.
 - s. All parking must be asphalt or concrete.
 - t. All sidewalks and walkways must be concrete and be at least 5-feet wide. Sidewalks servicing a single unit may be three (3) feet wide.
 - u. All driveways on single-family homes must be concrete.
 - v. All above ground concrete shall be minimum 3500 PSI with 6X6 welded wire reinforcement to ensure quality, strength and uniformity.
 - w. All new construction buildings must have radiant barrier in attics or on roofs.
3. Interior Building and Space Standards:
- a. Kitchen spaces:
 - (i.) Each unit must be equipped with a dry chemical fire extinguisher readily accessible in the kitchen.
 - (ii.) New cabinets must have dual sidetrack drawers.
 - (iii.) A pantry closet is required in each unit. The pantry must be 1'6" x 1'6" deep with a minimum five shelves, located in the kitchen.
 - (iv.) All units shall include a kitchen area which includes at a minimum, a sink, stove and refrigerator.
 - b. Bathroom Spaces:
 - (i.) Tub/shower units should have minimum dimensions of 30-inch width by 60-inch length. Units in senior and assisted living developments must be equipped with anti-scald valves.
 - (ii.) Water closets should be centered 18 inches from sidewalls or vanity/lavatories.
 - c. Hallways should have a minimum width of 36 inches.
 - d. All interior doors intended for passage must have minimum clear opening width of 34 inches.
 - e. Overhead lighting is required in each room.
 - f. Sliding glass doors are prohibited.
 - g. A tamper-proof 10-year smoke alarm is required per floor of each unit.
 - h. A carbon monoxide detector must be installed in each unit. (only for developments using gas).
4. Plumbing and Mechanical Equipment:
- a. HVAC units and water heaters are not permitted in attic spaces.
 - b. HVAC units and water heaters must be placed in mechanical closets with insulated walls.
 - c. Water heaters must be placed in drain pans with drain piping plumbed to the outside.
 - d. Gas water heaters shall be located in an individual, separate mechanical closet.
 - e. HVAC refrigeration lines must be insulated.
5. Energy Efficient Systems, Insulation, and Equipment.
- a. Ceiling fans will be installed in each bedroom and living room.
 - b. Shower heads will not exceed a 2.5 gallon per minute flow rate.
 - c. 1/2" insulation will wrap hot water pipes
 - d. Light-emitting diode (LED) lighting features will be installed in the kitchen, bathroom(s) and utility room area.
 - e. Exterior wall insulation must have an overall R-16 minimum for the entire wall assembly.
 - f. An exterior house wrap (e.g. TYVEK) must be installed.
 - g. Roof or attic insulation must have an R-38 minimum rating.
 - h. All water piping located on exterior walls and in attic space must be insulated.
 - i. Sound proofing or insulation achieving a sound rating of STC 54 is required in common/party walls and ceilings.
 - j. Gas or oil heated systems shall have a minimum AFUE rating of 90% with a minimum 14.5 SEER rated air conditioning system.
 - k. Heat pump systems shall have minimum HSPF rating of 7.8 with a minimum 14.5 SEER rated air conditioning system.
 - l. Windows shall have frames and sashes constructed of wood, vinyl-clad wood, or extruded vinyl. Windows shall have two or more panes of insulated glass, at least one

pane of which has a Low-Emission (Low-E) coating, which are argon gas filled. Windows shall have a U-Factor of not greater than 0.35 and a solar heat gain coefficient (SHGC) of not greater than 0.30.

For rehabilitation developments, if any of the above elements cannot be included in any building because of structural constraints, an energy audit or report, performed by an independent, professional energy consultant/audit firm, which identifies those constraints but enumerates:

- i. Other effective energy improvements or energy performance measures designed to increase energy efficiency in the particular building; and
- ii. The energy efficiency to be achieved by such improvements of measures on the particular building. The energy audit or report shall describe the methodology/testing procedures utilized.

The applicant must submit a signed statement that it will implement the energy improvements or energy performance measures identified within the energy audit or report in order to be considered for points under this criterion. Also, a certification from the design architect or licensed engineer confirming the implementation of the energy improvements or energy performance measures will be required prior to the issuance of IRS Form 8609.

V. Universal Design Criteria:

- A. Seven percent (7%) of all residential units within the development must comply with the Level 5, "All-Inclusive" usability criteria as set forth in the Arkansas Department of Human Services' "Arkansas Usability Standards in Housing: Guidance Manual for Constructing Inclusive Functional Dwellings." (AUSH). The AUSH is available on the internet at: https://adfa.arkansas.gov/media/file/AR_Standards_in_Housing.pdf
- B. Each unit that is required to meet the Level 5, "All-Inclusive" usability criteria set forth in the AUSH must have at least one bathroom with an "accessible roll-in" shower facility with minimum dimensions of 60" x 34" or 36" x 36" if a corner shower facility.
- C. All ground level residential units in any building and all residential units with elevator access in any building in the development must comply with the Level 1, "Visitable" usability criteria as set forth in the AUSH.
- D. All residential units in the development will have "closed-fist" operability throughout the unit, e.g., single handle door levers vs. door knobs; push stick lighting and environmental controls; cabinet doors can be opened with a closed fist; single handle faucets in bathrooms and kitchen.
- E. All environmental controls within all residential units in the development must provide visual and tactile cues. For lighting, a "rocker" type switch is sufficient. For thermostats, programmable and digital with raised buttons is required.

VI. Rehabilitation developments:

If structural constraints prohibit adherence to ADFA's "Multifamily Housing Minimum Design Standards", applicant may seek a waiver from ADFA of the standard concerned. Such waiver request must be in writing and include the following:

- A. Certification by the design architect or licensed engineer that the standard concerned cannot be met due to structural constraints;
- B. Certification by the design architect or licensed engineer that no alternative design can be undertaken to achieve the benefit of the required standard due to structural constraints; and
- C. If applicable, statement by applicant that it will implement any alternative identified by the design architect or licensed engineer.

ADFA reserves the right to amend these Minimum Design Standards as necessary to prudently administer ADFA-administered funds or to comply with state or federal law. ADFA reserves the right to adopt rules ancillary to these Minimum Design Standards as necessary to prudently administer ADFA-administered funds. ADFA reserves the right to make any and all necessary technical changes to these Minimum Design Standards as circumstances may warrant. ADFA reserves the right to do or require all things necessary or convenient to carry out its purposes, pursuant to Ark. Code Ann. Section 15-5-207(b)(20)(A) and Ark. Code Ann. Section 15-5-207(b)(26).